

## EU Declaration of Conformity (in accordance with 93/68/EEC)

We, Pyronix Limited, located at the above address declare under our sole responsibility that the products, to which this declaration relates, meet the essential requirements and are in conformity with the relevant EU requirements.

**Certificate number: PYR009 Issue 7**

**We accept all the responsibilities for the products mentioned below.**

**The Products Covered by this Declaration:**

Model Number	Product Name
EURO-46S	10-46 Input Panel [EoL], Power Supply & LCD RKP (EUR-064*)
EURO-46SM	10-46 Input Panel [EoL], Modem#, Power Supply & LCD RKP (EUR-064*)
EURO-46L	10-46 Input Panel [EoL], Power Supply & LCD RKP (EUR-064*)
EURO-46LM	10-46 Input Panel [EoL], Modem#, Power Supply & LCD RKP (EUR-064*)
EURO-APP46S	EURO46-APPS UK v2.1
EURO-APP46L	EURO46-APPL UK v2.1
EURO-APP46S	EURO46-APPS UK v10.0
EURO-APP46L	EURO46-APPL UK v10.0

Mentioned model numbers above are under the coverage of these directives (apart from \*).

**The EU Directives covered by this Declaration:**

2014/30/EU - EU Electro Magnetic Compatibility Directive EMC

2014/35/EU – EU Low Voltage Directive (LVD)

2011/65/EU - EU RoHS restriction of the use of certain hazardous substances in electrical and electronic equipment

#1999/5/EC - Radio Equipment and Telecommunication Terminal Equipment directive.

**The Basis on which Conformity is being declared:**

The products identified above comply with the requirements of the above EU Directives by meeting the below standards though design and manufacturing processes.

**We hereby declare that these standards are valid for the products mentioned above.**

EN 61000-6-3:2007 + A1: 2011 EMC. Generic emission standard. Residential, commercial and light industry.

EN 50130-4: 2011 Immunity requirements for components of fire, intruder and social alarm systems.

BS EN 60950-1:2006 +A12: 2011 Information technology equipment. Safety. General requirements.

EN 50131-1: 2006 + A1: 2009 Alarm systems – Intrusion and hold-up systems – Part 1: System requirements

EN 50131-3: 2009 Alarm systems – Control and Indicating Equipment (CIE)

EN 50131-6: 2008 Alarm systems – Power supplies

#ETSI ES 203 021-1 V2.1.1/-2 V2.1.2/-3 V2.1.2 Access and Terminals (AT); Harmonized basic attachment requirements for Terminals for connection to analogue interfaces of the Telephone Networks; Update of the technical contents of TBR 021, EN 301 437, TBR 015, TBR 017; Part 1: General aspects; Part 2: Basic transmission and protection of the network from harm; Part 3: Basic Interworking with the Public Telephone Networks

#EN 41003:2009 Particular safety requirements for equipment to be connected to telecommunication networks and/or a cable distribution system

The technical documentation supporting this declaration is available at the above address for inspection by the relevant enforcement authorities.

The CE mark was first applied in: 2010.

The products described above comply with the essential requirements of the directives specified.

Name Steven Fazey Signed *Steven Fazey*  
 Authority Compliance Engineer Date 1<sup>st</sup> August 2017

### ATTENTION!

I hereby declare that the aforementioned products have been designed to comply with the relevant sections of the above referenced specifications. Pyronix Limited can only guarantee compliant operation when installed and operated according to the installation and user manuals that accompany the product(s).



Security Grade 2  
Environmental class 2  
PD6662: 2010

With fitted with a suitable ATS 2 (alarm transmission system) as per table 10 of EN 50131-1: 2006 + A1: 2009



Security Grade 3  
Environmental class 2  
PD6662: 2010

With fitted with a suitable ATS 4 or 5 (alarm transmission system) as per table 10 of EN 50131-1: 2006 + A1: 2009